


	Maine Coast Lab
	47 Gardiner Road
	Wiscasset, ME. 04578
	Phone: 207.882.5476
	Email: mainecoastlab@waterqualityme.com
	Web: waterqualityservicesme.com
	EPA Lab ID: ME01032

Report of Analyses Sample ID Number: WTR09222026 PWSID: ME0098233 Sample Site: Distribution Sample Source: Drinking Water Sample Received Date/Time: 9/22/26 1530	Client Whitetail Ridge 94 Whitetail Ridge Rd. Bridgton, ME 04009
--	---

Parameter	Results	Units	Acceptable Limit	Reporting Limit	Method	Sampled		Analysis Start		Analysis Complete	
						Date	Time	Date	Time	Date	Time
Total Coliform	Absent	P-A/100mL	Absent	P-A	SM 9223 B (Collert)	9/22/26	0955	9/23/26	1209	9/24/26	1220
E. Coli	Absent	P-A/100mL	Absent	P-A	SM 9223 B (Collert)	9/22/26	0955	9/23/26	1209	9/24/26	1220

Authorized Signature


 Jason G. Wilby, Lab Director

The Maine Coast Lab hereby certifies that all test results for the sample were analyzed by the method listed. These results reflect those obtained on the received sample. The report shall not be reproduced except in full without the written consent of the laboratory.

END OF REPORT

Processed: ST Proofed: 

Page 1 of 1

Maine Drinking Water Program

Laboratory ID

COLIFORM(TCR)-SEPTEMBER

WTR09222026

Please read the enclosed sampling instructions before collecting sample(s)

Frequency: Monthly

Public Water System Information

System Name: WHITE TAIL RIDGE ASSOCIATION

System Phone #:

PWSID Number: ME0098233

Address: 80 BEN HALE ROAD

WATERFORD, ME 04088

Sample Category: RT

System Type: COMMUNITY Chlorinated: No

Samplers Name: HARVEY, MICHAEL WQ & C

Laboratory Information

Laboratory Name Eurofins-Auburn

Lab Certification: ME01076

Lab Director: Amber Cusson

Lab Phone #: (207) 784-5354

Laboratory use ONLY

On Ice: ☒ N ☐

Initial Temp 3.3 °C Corrected Temp °C IR Gun#

DELIVERY: WALK IN ☐ MAIL ☐ UPS/FEED EX ☐ COURIER ☐ DROP BOX ☐

Paid: \$ Bill: \$ Check# CC

Required Analysis: COLIFORM(TCR)-SEPTEMBER

Is your system chlorinated? Yes ☐ No ☒ For chlorinated samples please circle FREE or TOTAL. Default value will be FREE.

of Samples: 1

#	Sample Point	Sampling Location (Per DWP Schedule)	Collection Point	Date & Time Sample Taken	Field Measurements			Comments
					Chlorine mg/L	Temp °C	pH	
1	DS-1	DIST SYS DISTRIBUTION SYSTEM	Distribution	9/22/26 9:55	16.6	8.3		

I/We understand this report will be submitted to the Maine Drinking Water Program.

Relinquished by Sampler: M. Estep	Date 9/22/26	Time 1530	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory: R. A. A.	Date 9/22/26	Time 1530